

# Compliance Document

No. D 111812 0017 Rev. 00

## E.6 Certificate of the network and system protection

<b>Certificate of NS protection</b>	<u>No. 50.409.22.0078.02-00</u>		
<b>Manufacturer</b>	<u>Suzhou Stealth Energy Technology Co., Ltd.</u> <u>8F, Zhenghe Mansion, No.198, Jinfeng Road, New</u> <u>District, 215000 Suzhou, PEOPLE'S REPUBLIC OF</u> <u>CHINA.</u>		
<b>Type of NS protection</b>			
<b>Central NS protection</b>	<input type="checkbox"/>		
<b>Integrated NS protection</b>	<input checked="" type="checkbox"/>	Assigned to power generation unit type	5 kW (ST-INV-T5.0) 6 kW (ST-INV-T6.0) 8 kW (ST-INV-T8.0) 10 kW (ST-INV-T10.0)
<b>Network connection rules</b>	<b>VDE-AR-N 4105:2018-11/Corrigendum 1:2020-10</b> Generators connected to the low-voltage distribution network - Technical requirements for the connection to and parallel operation with low-voltage distribution networks.		
<b>Test requirement</b>	<b>DIN VDE V 0124-100 (VDE V 0124-100):2020-06</b> <b>“Network integration of power generation system – Low voltage”</b> Test requirements for power generation units intended for connection to and parallel operation on the low-voltage network.		
The network and system protection mentioned above meets the requirements of VDE-AR-N 4105.			

# Compliance Document

No. D 111812 0017 Rev. 00

## E.7 Requirement for the test report for the NS protection

<b>Extract from test report for NS protection</b> "Determination of electrical properties"		No. 50.409.22.0078.02-00	
<b>NS protection test report</b>			
Type of NS system:	Integrated NS protection	<b>Other Manufacturer indications</b>	
Software version:	V1.1		
Manufacturer:	Suzhou Stealth Energy Technology Co., Ltd. 8F, Zhenghe Mansion, No.198, Jinfeng Road, New District, 215000 Suzhou, PEOPLE'S REPUBLIC OF CHINA.		
Measuring period:	From 2022-10-07 to 2023-03-02		
		<b>Inverter</b> directly coupled synchronous and asynchronous generators with $P_n > 50 \text{ kW}$	
Protection function	Setting value	Tripping value	Break time NS protection *
Rise-in-voltage protection $U >>$	$1.25 * U_n$	L1-N/L2-N/L3-N: 287 V, 287 V, 287 V, L1-N: 289 V, L2-N: 287 V, L3-N: 287 V, L1-L2: 498 V, L2-L3: 496 V, L3-L1: 497 V,	L1-N/L2-N/L3-N: 85 ms, L1-N: 92 ms, L2-N: 82 ms, L3-N: 97 ms, L1-L2: 76 ms, L2-L3: 65 ms, L3-L1: 71 ms,
Rise-in-voltage protection $U >$	$1.10 * U_n$	$1.0 * U_n$	ms**
Voltage drop protection $U <$	$0.8 * U_n$	L1-N/L2-N/L3-N: 184 V, 184 V, 184 V, L1-N: 184 V, L2-N: 183 V, L3-N: 183 V, L1-L2: 318 V, L2-L3: 318 V, L3-L1: 318 V,	L1-N/L2-N/L3-N: 3008 ms, L1-N: 3022 ms, L2-N: 3021 ms, L3-N: 3008 ms, L1-L2: 3017 ms, L2-L3: 3009 ms, L3-L1: 3010 ms,
Voltage drop protection $U <<$	$0.45 * U_n$	L1-N/L2-N/L3-N: 103 V, 103 V, 103 V, L1-N: 103 V, L2-N: 103 V, L3-N: 103 V, L1-L2: 178 V, L2-L3: 178 V, L3-L1: 178 V,	L1-N/L2-N/L3-N: 305 ms, L1-N: 333 ms, L2-N: 311 ms, L3-N: 311 ms, L1-L2: 313 ms, L2-L3: 314 ms, L3-L1: 322 ms,
Frequency decrease protection $f <$	47.5 Hz	47.49 Hz	72 ms
Frequency increase protection $f >$	51.5 Hz	51.50 Hz	57 ms